

- (f) The charging pressure of the cylinder at 15°C.
 - (g) The nominal water capacity of the cylinder.
 - (h) The tare weight of the cylinder.
 - (i) An identification that the cylinder is suitable for use with CNG.
2. That the cylinders be provided with valve threads of the form specified in British Standard BS 341 "Valve Fittings for Compressed Gas Cylinders".
3. That the cylinders be tested at periods not exceeding five years in accordance with the periodic test requirements laid down in the specification to which the cylinder was manufactured.
4. That the cylinder be provided with a cylinder shut off valve designed for a working pressure of 16.5 MPa and capable of withstanding the test pressure of the cylinder. Cylinder shut off valves shall be fitted with a hand wheel to facilitate ease of opening and closing of the valve and shall be fitted with a pressure relief device comprising of a burst disc backed by fusible alloy. The fusible alloy is to have a nominal yield temperature of 100°C and the burst disc shall yield at a pressure of not less than 24.75 MPa and not more than the test pressure of the cylinder. Cylinder valves shall be provided with an outlet thread of ¼ inch NPT (female) and a stem thread compatible with the cylinder neck thread.

Dated at Wellington this 19th day of February 1982.

T. A. LISTER, for Secretary for Transport.

CNG Fuel System Approvals

PURSUANT to regulation 90B of the Traffic Regulations 1976 (as inserted by the Traffic Regulations 1976 Amendment No. 7) and pursuant to the powers granted to me by the Secretary for Transport, I, Trevor Alan Lister, Senior Automotive Engineer, hereby approve the components listed in the Schedule hereto for inclusion in any CNG fuel system installed and operated in accordance with the requirements of New Zealand Standard NZS 5422, part 2, 1980 (and any standard made in amendment thereto or in substitution therefor) subject to the conditions (if any) set out in respect of any component in the said Schedule.

SCHEDULE
CNG FUEL CYLINDERS

Manufacturer	MOT Reference	Drawing Number	Material	Specification	Independent Inspection Authority	Nominal Water Capacity (litres)	Test Pressure (MPa)	Working Pressure Rating (MPa)
Faber, Italy	AF C03 085	203-300/93	Steel	ANCC rules	Lloyds	15	29.4	16.5
	AF C03 086			ANCC rules	Lloyds	16	29.4	16.5
	AF C03 087			ANCC rules	Lloyds	17	29.4	16.5
	AF C03 088			ANCC rules	Lloyds	18.5	29.4	16.5
	AF C03 089			ANCC rules	Lloyds	20	29.4	16.5
	AF C03 090			ANCC rules	Lloyds	22	29.4	16.5
	AF C03 091			ANCC rules	Lloyds	24	29.4	16.5
	AF C03 092			ANCC rules	Lloyds	27	29.4	16.5
Faber, Italy	AF C03 093	215-300/93	Steel	ANCC rules	Lloyds	17	29.4	16.5
	AF C03 094			ANCC rules	Lloyds	18	29.4	16.5
	AF C03 095			ANCC rules	Lloyds	20	29.4	16.5
	AF C03 096			ANCC rules	Lloyds	21	29.4	16.5
	AF C03 097			ANCC rules	Lloyds	22	29.4	16.5
	AF C03 098			ANCC rules	Lloyds	23	29.4	16.5
	AF C03 099			ANCC rules	Lloyds	24	29.4	16.5
	AF C03 100			ANCC rules	Lloyds	27	29.4	16.5

CNG cylinders are approved subject to the following conditions—

1. That they be permanently and clearly marked, either on a thickened portion of the cylinder or on a suitably attached metal plate, with characters not less than 6 mm high if space permits but in any case not less than 3 mm high, displaying the following information:
- (a) The specification to which the cylinder was manufactured.
 - (b) The manufacturers name or mark, and the serial number of the cylinder.
 - (c) The date of the original cylinder inspection and the identification mark of the inspection authority who made the inspection.
 - (d) The date of any periodic cylinder test and the identification mark of the cylinder testing station who made each test.
 - (e) The cylinder test pressure.
 - (f) The charging pressure of the cylinder at 15°C.
 - (g) The nominal water capacity of the cylinder.
 - (h) The tare weight of the cylinder.
 - (i) An identification that the cylinder is suitable for use with CNG.
2. That the cylinders be provided with valve threads of the form specified in British Standard BS 341 "Valve Fittings for Compressed Gas Cylinders".
3. That the cylinders be tested at periods not exceeding five years in accordance with the periodic test requirements laid down in the specification to which the cylinder was manufactured.
4. That the cylinder be provided with a cylinder shut off valve designed for a working pressure of 16.5 MPa and capable of withstanding the test pressure of the cylinder. Cylinder shut off valves shall be fitted with a hand wheel to facilitate ease of opening and closing of the valve and shall be fitted with a pressure relief device comprising of a burst disc backed by fusible alloy. The fusible alloy is to have a nominal yield temperature of 100°C and the burst disc shall yield at a pressure of not less than 24.75 MPa and not more than the test pressure of the cylinder. Cylinder valves shall be provided with an outlet thread of ¼ inch NPT (female) and a stem thread compatible with the cylinder neck thread.

Dated at Wellington this 19th day of February 1982.

T. A. LISTER, for Secretary for Transport.